

Field Advisory Unloading Adapters & Filler Valves 8/14/09

We have recently become aware of an incident where a Sherwood Unloading Adapter PV902A was misused when connected to the filler valve on the 8593AR16.0 Multivalve. It appears that excessive torque was applied by the Sherwood device when it was used to open the back checks in the filler valve, resulting in damage to the back check assembly. Sherwood's PV902A and PV902B, according to the Sherwood catalog, may only be used with the PV632A Sherwood filler valve because "use with any other filler valve may cause damage to the valve, and a proper seal may not be maintained".

The Sherwood PV902A & PV902B have a guide attached to the bottom of the adapter



To insure that RegO Products filler valves are not exposed to check assembly damage when it is necessary to utilize an unloading adapter; **use ONLY RegO Products 3119A, 3120 and 3121 unloading adapters with RegO Products filler valves** carefully follow the instructions supplied with these unloading adapters. If you require additional copies, for the 3119A, 3120 or 3121 contact your Authorized RegO Products Distributor or us by phone, or fax, or e-mail.

**3119A****3120****3121**

The RegO Products Filler Valves listed below should only be used with the RegO Products 3119A, 3120 or 3121 unloading adapters.

3174C
6579
7879
F7579I7579
7579
7579P
7579S8593AR16.0
G8475RV
G8475RW

Should you require additional information or have questions please contact us at the above phone or fax number or our website.