

# Excess Flow Valve for DOT Cylinders 3199W

## Application

Designed for use on portable systems with vapor or liquid including torches, heaters, lead melting burners, tar and asphalt burners, wallpaper steamers and other applications involving portable DOT cylinders. The POL inlet attaches directly to the cylinder valve and the outlet mounts to the regulator.

## Features

- Integral ball check design.
- Machined groove designed to break-off and allow excess flow valve ball to close.

## Materials



Body .....	Brass
Nut .....	Brass
Bell.....	Stainless Steel
Spring .....	Stainless Steel
Retainer Spring.....	Stainless Steel
Retainer.....	Brass



## Ordering Information



**3199W**



Typical Installation

### NOTE:

No protection is afforded should break-off occur downstream of the groove. Also, restrictions introduced by the regulator may prevent closing of the valve due to limited flow capacity. The valve's purpose is to protect the cylinder valve outlet should the regulator be broken off of its connection (at the groove), in which case it will close. It must not be depended upon to protect against breaks downstream of the regulator.

Part Number	A. Inlet Connection	B. Outlet Connection	C. Wrench Hex Flats	D. Effective Length (Approx.)	Approximate Closing Flow*		
					Liquid (GPM Propane)	Vapor SCFH (Propane)	
						25 PSIG Inlet	100 PSIG Inlet
<b>3199W</b>	Male POL	1/4"	7/8"	2 7/16"	.95	265	500

\* Based on horizontal installation of excess flow valve. Flows are slightly more when valves are installed with outlet up; slightly less when installed with outlet down.  
NOTE: Multiply flow rate by .94 to determine liquid butane flow.