

PRESSURE VESSEL ENGINEERING
B-120 RANDALL DRIVE
WATERLOO ON N2V 1C6
CANADA

Date: March 22, 2021
Account #: 45363
Journal #: 77512

Attn: MARY

Re: Application for Design Registration

The design, as detailed in your, PVE-16046-2, for a Fitting is accepted for registration as follows:

Registered To: ENGINEERED CONTROLS **CRN:** 0C23020.51
INTERNATIONAL LLC

Drawing #: 16046s-2

Drawing Revision: 0

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Reviewer's Notes:

As required by CSA B51 4.2.1, this registration expires on 19-Feb-2031. This CRN is valid until the expiry date as long as the Manufacturer maintains a valid quality control program verified by an acceptable third-party agency until that date. Should the certification of the quality control program lapse before the expiry date, this registration shall become void. Any additional conditions of registration stated in TSSA CRN# 0C23020.5 registration shall apply to BC registration.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

Janina Mihailescu

janina.mihailescu@technicalsaftybc.ca
Design Administration

cc:

March 15, 2021

Attention: Catherine Diplock
PRESSURE VESSEL ENGINEERING INC
120 RANDALL DRIVE SUITE B
WATERLOO, ON N2V 1C6

The design submission, tracking number 2021-00917, originally received on February 22, 2021 was surveyed and accepted for registration as follows:

CRN : 0C23020.52 **Accepted on:** March 15, 2021
Reg Type: NEW DESIGN **Expiry Date:** February 19, 2031
Drawing No. : RS3131 SER. REV.J; SCOPE 16046S-2,R0 As Noted
Fitting type: VALVE , 3/4 NPSM

Design registered in the name of : ENGINEERED CONTROLS INTERNATIONAL LLC

Description	MAWP	Design Temperature	MDMT
Internal Pressure	3309kPa	74 °C	-40 °C

The registration is conditional on your compliance with the following notes:

This valve shall not be used as a primary Safety Pressure Relief Valve for pressure systems overpressure protection.

As indicated on AB-41 Statutory Declaration form and submitted documentation, the code of construction is ASME B31.3.

- It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.*
- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form.*
- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date.*
- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.*

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3330 or fax (780) 437-7787 or e-mail grynchuk@absa.ca.

Sincerely,



GRYNCHUK, MILLA, P. Eng.
DOP Cert. No. D00005217



the pressure equipment safety authority

9410 - 20 Ave N.W.
Edmonton, Alberta, Canada T6N 0A4
Tel: (780) 437-9100 / Fax: (780) 437-7787

March 15, 2021

REGISTRATION OF A PRESSURE FITTING DESIGN

08-Mar-21

Pressure Vessel Engineering Ltd.
120 Randall Drive, Suite B
Waterloo, ON
N2V 1C6

Attention: Catherine Diplock

File Number: 11935 [0 F]

Re: Manufacturer: Engineered Controls International LLC
Item: Relief Valve
Catalog or Drawing: Scope for Registration: 16046s-2 R0

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations and CSA B51. The Canadian Registration Number (CRN) is:

0C23020.53 Expiry Date: February 19, 2031

Please note that every fitting shall be constructed in strict accordance with the registered design.

Fitting registrations are required to be resubmitted for validation after ten (10) years from the registration date in accordance with CSA B51, Clause 4.2.1.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Williams Uju, P.Eng.
Codes and Standards Compliance

Remarks:

CRN registered conditional upon compliance with the notes on the original registration.

A valid quality control program must be maintained at the production facility for the fitting registration to remain valid until the expiry date.

This fitting can be manufactured by Shanghai Rego Flow Technology Co., Ltd.

A statutory declaration form, TSK-1008, stamped and signed by a commissioner of oaths, must be submitted to TSASK.



Inspection and Technical Services
Municipal Relations
508-401 York Ave
Winnipeg, Manitoba Canada R3C 0P8
T 204-945-3373 F 204-948-2089
www.firecomm.gov.mb.ca/itsm_main

2/23/2021

Pressure Vessel Engineering Ltd.
120 Randall Drive, Suite B
Waterloo, ON N2V 1C6
CA

Dear Catherine Diplock

Re: Reciprocal CRN Registration in Manitoba

Your application indicates that a CRN has been received in another Canadian Jurisdiction, and therefore your CRN has been registered in Manitoba as follows:

File Number: 74-R1318
CRN: 0C23020.54
Scope: Refer to Scope 16046s-2 R0
Manufacturer: Engineered Controls International LLC
Expiry Date: 19/Feb/31

Please find attached invoice for registration.

As indicated by the Regulatory Reconciliation and Cooperation Table and the Reconciliation Agreement for the Canadian Registration Number (CRN) for Pressure Equipment, a CRN issued in any Canadian Jurisdiction will be accepted for use in Manitoba.

In accordance with Steam and Pressure Plants Regulation and CSA B51, it is the manufacturer's responsibility to file a Manufacturers Data Report, including partial data reports, with our office, prior to shipping pressure equipment to Manitoba.

Please contact qasupport@gov.mb.ca for any questions or concerns.

Inspection and Technical Services
Municipal Relations
508 - 401 York Avenue, Winnipeg Manitoba R3C 0P8
T (204) 945-3373 | F (204) 948-2089



Technical Standards and Safety Authority
 345 Carlingview Drive
 Toronto, Ontario M9W 6N9
 www.tssa.org

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below



STATUTORY DECLARATION Registration of Fittings

I, Zachary Rubear, Design Engineer
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of Engineered Controls International LLC
(Name of Manufacturer)

Located at 100 Rego Drive, Elon, NC 27244, USA
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of

_____ (Title of recognized North American Standard)
 which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with ASME B31.3 2018 Edition as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of _____ ISO 9001:2015 which has been verified by the following authority, DQC Inc.

The items covered by this declaration, for which I seek registration, are category C type fittings. In support of this application, the following information and/or test data are attached as follows:

Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131 SER
(drawings, calculations, test reports, etc.)

Declared before me at _____ in the _____ of _____

the _____ day of _____ AD _____.

Commissioner for Oaths:

(Printed name)

(Signature)

Zachary Rubear
(Signature of Declarer)

FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category C.

CRN: 0C23020.5

Registered by: NORMAN NGAI

Dated: Feb. 19, 2021.

NOTE: This registration expires on: Feb. 19, 2031.

Technical Standards and Safety Authority Boilers and Pressure Vessels Safety Program
REGISTERED
 C.R.N.: 0C23020.5
 Signed: Norman Ngai
 Date: February 19, 2021.

Registration notes:
 Please refer to scope for detail of registration.
 Two manufacturing locations.



Technical Standards and Safety Authority
 345 Carlingview Drive
 Toronto, Ontario M9W 6N9
 www.tssa.org

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below



STATUTORY DECLARATION Registration of Fittings

I, Zachary Rubear, Design Engineer
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of Shanghai Rego Flow Technology Co., Ltd.
(Name of Manufacturer)

Located at 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of

(Title of recognized North American Standard)
 which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with ASME B31.3 2018 Edition as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001:2015 which has been verified by the following authority, CQC.

The items covered by this declaration, for which I seek registration, are category C type fittings. In support of this application, the following information and/or test data are attached as follows:

Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131-SER
(drawings, calculations, test reports, etc.)

Declared before me at _____ in the _____ of _____

the _____ day of _____ AD _____.

Commissioner for Oaths:

(Printed name)

(Signature)

Zachary Rubear
(Signature of Declarer)

FOR OFFICE USE ONLY

To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category _____.

CRN: _____

Registered by: _____

Dated: _____

NOTE: This registration expires on: _____



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772

www.tssa.org

February 19, 2021

CATHERINE DIPLOCK
PRESSURE VESSEL ENGINEERING LTD.
120 RANDALL DR SUITE B
WATERLOO ON N2V 1C6
CA

Service Request Type: BPV-Fitting Registration
Service Request No.: 2998798
Your Reference No.: PVE-16046
Registered to: REGO PRODUCTS

Dear CATHERINE DIPLOCK,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN No.: 0C23020.5
Main Design No.: REFER TO SCOPE 16046s-2 R0
Expiry Date: 19-Feb-2031

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

Note:

Please refer to scope for detail of registration.
Two manufacturing locations.

The stamped copy of the approved registration and the invoice are mailed separately. Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Norman Ngai, P. Eng.
Mechanical Engineer
Boilers and Pressure Vessels
Safety Program
Tel. : 416-734-3557
Fax : 416-231-6183
Email : nngai@tssa.org
www.tssa.org

Montréal, 6 avril 2021.

MADAME CATHERINE DIPLOCK
PRESSURE VESSEL ENGINEERING LTD
120 RANDALL DR., SUITE B
WATERLOO ONTARIO
CANADA N2V 1C6

Fabricant : ENGINEERED CONTROLS INTERNATIONAL INC.
100 REGO DRIVE
ELON NORTH CAROLINA
U.S.A. 27244

Numéro de dossier : 949874
Numéro(s) de dessin(s) : REFER SCOPE 16046S-2 R0

Objet : Enregistrement des plans et devis – Confirmation de l'enregistrement

Bonjour,

Nous vous informons que votre demande d'enregistrement de plans et devis a été traitée et que cette conception a été enregistrée sous le numéro d'enregistrement canadien (NEC\CRN) suivant : **0C23020.56**.

Nous portons votre attention sur certaines exigences réglementaires concernant les installations sous pression, ainsi que des codes et normes qui y sont associés :

- Le fabricant doit maintenir un programme de contrôle de la qualité valide pour fabriquer un équipement selon ce NEC;
- Ce numéro d'enregistrement demeure valide tant et aussi longtemps que les paramètres de conception demeurent inchangés. Dans le cas d'accessoires, l'enregistrement est valide pour une durée de 10 ans à partir de la date d'enregistrement. Les documents de conception doivent alors être resoumis pour validation;
- Le fabricant doit nous transmettre une copie de la *Déclaration de conformité du constructeur (Manufacturer's Data Report)* pour chaque appareil ou chaudière fabriqué selon ce NEC dans les 30 jours suivant la signature de cette déclaration;
- Le numéro de dessin enregistré et le numéro de révision doivent être indiqués sur la déclaration de conformité pour les équipements fabriqués selon ce NEC.

Le présent avis d'approbation ne dégage pas le fabricant de ses responsabilités quant à la conception ou à la construction des équipements ou d'accessoires fabriqués selon un NEC.

Bureau d'expertise et d'homologation en équipements sous pression

Montréal

545, boul. Crémazie Est, 7ième étage

Montréal (Québec) H2M 2V2

Téléphone : 514 873-6459

Sans frais : 1 866 262-2084

www.rbq.gouv.qc.ca

Montréal, le 6 avril 2021.

MRS. CATHERINE DIPLOCK
PRESSURE VESSEL ENGINEERING LTD
120 RANDALL DR., SUITE B
WATERLOO ONTARIO
CANADA N2V 1C6

Manufacturer : ENGINEERED CONTROLS INTERNATIONAL INC.
100 REGO DRIVE
ELON NORTH CAROLINA
U.S.A. 27244

OUR REFERENCE : 949874
Design number : REFER SCOPE 16046S-2 R0

Subject: Design registration confirmation

Hi,

We wish to inform you that your design registration application has been evaluated and that it was registered under the following Canadian Registration Number (CRN): **0C23020.56**.

The following is a reminder of your obligations regarding certain requirements of the regulation respecting pressure vessels, and the referenced codes and standards:

- The manufacturer must maintain a valid quality control program to manufacture equipment according to the CRN.
- The CRN remains valid as long as there are no changes to the design calculations that might affect the pressure boundary. The design registration of fittings expires 10 years after acceptance. It must, therefore, be resubmitted for validation.
- The manufacturer shall submit a copy of the *Manufacturer's Data Report* to us for each equipment manufactured according to this CRN within 30 days following the signing of this report.
- The drawing number and the revision number registered under this CRN must be indicated on the *Manufacturer's Data Report* for equipment manufactured according to the CRN.

This notice of approval does not relieve the manufacturer of their responsibilities with respect to the design or fabrication of equipment manufactured according to this CRN.

Yours sincerely,

Bureau d'expertise et d'homologation en équipements sous pression

Montréal

545, boul. Crémazie Est, 7ième étage
Montréal (Québec) H2M 2V2
Téléphone : 514 873-6459
Sans frais : 1 866 262-2084
www.rbq.gouv.qc.ca

Building Act (B-1.1)
Regulation respecting pressure vessels (B-1.1, r. 6.1)
Boiler, pressure vessel, and pressure piping code (CSA B51)



This declaration must be filled out and sent to the Régie du bâtiment du Québec (RBQ) by pressure fitting manufacturers when they make an application registration for fittings.

For more information on the application registration for fittings, consult the www.rbq.gouv.qc.ca/fittings-pv.

1. Fittings to register

List the fittings included in this declaration and that you wish to register.

N°	Description	Additional information (detail, calculations or approval sheets)
1	refer scope document: 16046s-2	Calculation # 16046c-2 R0
2		
3		
4		
5		

2. Declaration of the person in charge

The person in charge is someone in a position of authority, such as a vice-president, a plant manager or a chief engineer.

2.1 Design

I, the undersigned, Zachary Rubeor Design Engineer
(Name of the person in charge) (Title of the person in charge)

from Shanghai Rego Flow Technology Co., Ltd., located at 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China
(Company's name) (Plant's address)

hereby declare that the above-mentioned fittings and subject to the Regulation respecting pressure installations:

comply with the requirements of the ANSI/ASME codes as to their dimensions, identification, material and purpose
or
 are not covered by the ANSI/ASME codes, but are in compliance with ASME B31.3 2018 Edition
(Name of code or standard)

code or standard and are designed according to the best current engineering practice, as proven by the enclosed approval report.

2.2 Manufacturing quality control

I further declare that the manufacture of these fittings is controlled by a quality control program that complies with the requirements of the following code: ISO 9001:2015, and has been verified by CQC
(Name of code) (Authorized agency)

Signature of the person in charge: Zachary Rubeor Date (yyyy-mm-dd): 2020-11-03

3. Declaration of commissioner for oaths

I certify that this declaration has been administered before me, at _____, on _____.
(Location) (Date (yyyy-mm-dd)):

Signature of commissioner for oaths:

Date (yyyy-mm-dd):

Stamp the seal:

4. Registration confirmation (for RBQ's use only)

As far as I know, this application complies with the requirements of the Act and with standard CSA B51, Part 1, section 4.2, and is accepted for registration in the class _____.

This registration expires in ten (10) years after the date of registration indicated above, and it must be validated again after this period.

Canadian registration number (CRN):

Registration date (yyyy-mm-dd):



Documents to attach

Any application registration for fittings must include these documents:

- Statutory Declaration Registration of Fittings (2 copies)
- Detailed calculations or burst test report (1 copy)
- Detailed technical drawings or catalogues (2 copies)
- Example of the manufacturer's marking (1 copy)
- Proof that a valid and approved quality control program has been implemented (1 copy)
- Form Application for design registration (1 copy)

Sending the form

This declaration is mandatory in order to submit an application registration of fittings.

Application registration for fittings must only be sent by mail to this address:

Bureau d'expertise et d'homologation en équipements sous pression

Régie du bâtiment du Québec

545, boulevard Crémazie Est, 7^e étage

Montréal (Québec) H2M 2V2

Building Act (B-1.1)
Regulation respecting pressure vessels (B-1.1, r. 6.1)
Boiler, pressure vessel, and pressure piping code (CSA B51)



This declaration must be filled out and sent to the Régie du bâtiment du Québec (RBQ) by pressure fitting manufacturers when they make an application registration for fittings.

For more information on the application registration for fittings, consult the www.rbq.gouv.qc.ca/fittings-pv.

1. Fittings to register

List the fittings included in this declaration and that you wish to register.

N°	Description	Additional information (detail, calculations or approval sheets)
1	refer scope document: 16046s-2	Calculation # 16046c-2 R0
2		
3		
4		
5		

2. Declaration of the person in charge

The person in charge is someone in a position of authority, such as a vice-president, a plant manager or a chief engineer.

2.1 Design

I, the undersigned, Zachary Rubeor Design Engineer
(Name of the person in charge) (Title of the person in charge)

from Engineered Controls International LLC, located at 100 Rego Drive, Elon, NC 27244, USA
(Company's name) (Plant's address)

hereby declare that the above-mentioned fittings and subject to the Regulation respecting pressure installations:

comply with the requirements of the ANSI/ASME codes as to their dimensions, identification, material and purpose
or

are not covered by the ANSI/ASME codes, but are in compliance with ASME B31.3 2018 Edition
(Name of code or standard)

code or standard and are designed according to the best current engineering practice, as proven by the enclosed approval report.

2.2 Manufacturing quality control

I further declare that the manufacture of these fittings is controlled by a quality control program that complies with the requirements of the following code: ISO 9001:2015, and has been verified by DQC Inc.
(Name of code) (Authorized agency)

Signature of the person in charge: Zachary Rubeor Date (yyyy-mm-dd): 2020-11-03

3. Declaration of commissioner for oaths

I certify that this declaration has been administered before me, at _____, on _____.
(Location) (Date (yyyy-mm-dd)):

Signature of commissioner for oaths:

Date (yyyy-mm-dd):

Stamp the seal:


4. Registration confirmation (for RBQ's use only)

As far as I know, this application complies with the requirements of the Act and with standard CSA B51, Part 1, section 4.2, and is accepted for registration in the class _____.

This registration expires in ten (10) years after the date of registration indicated above, and it must be validated again after this period.

Canadian registration number (CRN):

Registration date (yyyy-mm-dd):



Documents to attach

Any application registration for fittings must include these documents:

- Statutory Declaration Registration of Fittings (2 copies)
- Detailed calculations or burst test report (1 copy)
- Detailed technical drawings or catalogues (2 copies)
- Example of the manufacturer's marking (1 copy)
- Proof that a valid and approved quality control program has been implemented (1 copy)
- Form Application for design registration (1 copy)

Sending the form

This declaration is mandatory in order to submit an application registration of fittings.

Application registration for fittings must only be sent by mail to this address:

Bureau d'expertise et d'homologation en équipements sous pression
Régie du bâtiment du Québec
545, boulevard Crémazie Est, 7^e étage
Montréal (Québec) H2M 2V2

Doc: 16046s-2 R0
 Ref: PVE-16046

The scope of registration for this project includes the documents and design dated noted herein. **(Cat. C fitting)**
 Design Code: ASME B31.3 2018 Edition

Scope for Registration

Category	Series/Family Part Number	Description	Listed Part Numbers	Connection Size	Drawings	Material	Min Temp (F)	Max Temp (F)	Max Design Pressure (PSI)
Type C Fitting	RS3131 SER	Relief Valve	RS3131B15.7 RS3131B17.2 RS3131B17.65 RS3131B375 RS3131B375L	3/4 NPSM	RS3131 SER	n/a	-40	165	480
					RS3131-1	ASTM B283, UNS C37700 BRASS			
					RS3131-1F	ASTM B283, UNS C37700 BRASS			
						CUZn40PB2, CW617N, H080 COPPER ZINC ALLOY, EN12165			
11550-160	ASTM B283, UNS C37700 BRASS								

Calculations

- 16046c-2 R0

QC Certificate:

- QC Certificate ISO 9001:2015 and notarized statutory declaration form

Holder Information:

Name: Engineered Controls International LLC
 Address: 100 Rego Drive, Elon, NC 27244, USA
 Company Contact: Zachary Rubeor, Design Engineer
 Contact Phone: 1-336-446-7219
 Contact Email: zrubeor@regoproducts.com


Manufacturing Locations:

All CRNs should be assigned to Engineered Controls International LLC, but some subsidiary companies may be listed on the attached quality certificates. For simplicity, the subsidiary's name is also listed in this document in association with its manufacturing location. Please register all products for production at both facilities.

1. Engineered Controls International LLC (ECII) – 100 Rego Drive, Elon, NC 27244, USA
2. Shanghai Rego Flow Technology Co., Ltd. (ECII China) – 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Engineered Controls International LLC	
MANUFACTURERS ADDRESS: 100 Rego Drive, Elon, NC 27244, USA	
PLANT LOCATIONS: Refer scope document # 16046s-2	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>, (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center">ASME B31.3 2018 Edition</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div align="center" style="font-size: 2em; font-weight: bold; margin: 10px 0;">REGO[®]</div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/></p> <p>CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/></p> <p>DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Refer scope document # 16046s-2</p> <p>Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131 SER</p>	

DECLARATION:


I Zachary Ruber (see note 3) employed by Engineered Controls International and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DQC Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Ruber

Declared before me at _____

This 19th day of February AD 2021

Commissioner of Oaths
or Notary Public: (sign) _____



**DEPT OF JUSTICE PUBLIC SAFETY
BOILER & PRESSURE VESSEL ACT**

This space for Regulatory Authority use

This registration must be revalidated after ten (10) years from the date of acceptance.

REGISTRATION ONLY

CRN OC23020.57

Pam Aross
CHIEF BOILER INSPECTOR

DATE 3/5/2021

BLRs PVs

FITTINGS NUCLEAR COMPONENTS

Sect. 1.0 - Fittings Rev. 1 06/2003

CRN: OC23020.5

FID#: 1704

RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F

Notes:

- All fittings shall be registered in the name of the Manufacturer.
- Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.
- The declaration shall be made by the person having full authority and responsibility for the quality of the end product.
- Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.

CRN expires Feb. 19th, 2031 - DG

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON


PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shanghai Rego Flow Technology Co., Ltd.	
MANUFACTURERS ADDRESS: 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China	
PLANT LOCATIONS: Refer scope document # 16046s-2	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY <input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2018 Edition
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT <div style="text-align: center; font-size: 2em; font-weight: bold; letter-spacing: 0.5em;">REGO</div>	TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: Refer scope document # 16046s-2 Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131-SER	

DECLARATION:
 I, Zachary Rubes (see note 3) employed by Shanghai Rego Flow Technology and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by CQC as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Rubes
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____



This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance. CRN: <u>0C23020.5</u> FID#: <u>1704</u> RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. CRN expires Feb.19th, 2031 - DG	REGISTRATION ONLY CRN <u>0C23020.57</u> CHIEF BOILER INSPECTOR DATE <u>3/5/2021</u> <input type="checkbox"/> BLRs <input type="checkbox"/> PVs <input checked="" type="checkbox"/> FITTINGS <input type="checkbox"/> NSL
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Engineered Controls International LLC	
MANUFACTURERS ADDRESS: 100 Rego Drive, Elon, NC 27244, USA	
PLANT LOCATIONS: Refer scope document # 18046a-2	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY	
<input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> . (Meeting CNSC or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2018 Edition
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	
	TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: Refer scope document # 18046a-2 Calculation # 18046c-2 R0, scope document # 18046a-2 and Main dwg# RS3131 SER	

DECLARATION:
 I, Zachary Rubear (see note 3) employed by Engineered Controls International and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure, temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DGC Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Rubear
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR
OFFICIAL SEAL

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C23020.5</u>	
FID#: <u>1704</u>	
RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F	
Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. CRN expires Feb. 19th, 2031 - DG	


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shanghai Rego Flow Technology Co., Ltd.	
MANUFACTURERS ADDRESS: 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China	
PLANT LOCATIONS: Refer scope document # 16046a-2	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY	
<input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> . (Meeting CNSC or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2018 Edition
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	
	TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:	
Refer scope document # 16046s-2	
Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131-SER	

DECLARATION:
 I, Zachary Ruben (see note 3) employed by Shanghai Rego Flow Technology, and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by CQC as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.


Signature of Declarer: Zachary Ruben
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR
OFFICIAL SEAL

This space for Regulatory Authority use
 This registration must be revalidated after ten (10) years from the date of acceptance.

CRN: 0C23020.5
 FID#: 1704
 RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F

Notes:
 1. All fittings shall be registered in the name of the Manufacturer.
 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.
 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.
 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.
 CRN expires Feb.19th, 2031 - DG



1.0 - Fittings Rev. 1 06/2003

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Engineered Controls International LLC	
MANUFACTURERS ADDRESS: 100 Rego Drive, Elon, NC 27244, USA	
PLANT LOCATIONS: Refer scope document # 16046s-2	
<p>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p>TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3 2018 Edition</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <p align="center">REGO</p>	<p>TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Refer scope document # 16046s-2</p> <p>Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131 SER</p>	

DECLARATION:

I, Zachary Rubcor (see note 3) employed by Engineered Controls International and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DQC Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Rubcor
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR THE
OFFICIAL SEAL

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C23020.5</u> FID#: <u>1704</u> RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. CRN expires Feb 19th, 2031 - DG	ACCEPTED PROVINCE OF PRINCE EDWARD ISLAND COMMUNITIES, LAND & ENVIRONMENT C.R.N. <u>0C23020.59</u> DATE: <u>March 5/21</u> _____ INSPECTION SERVICES SECTION BOILER/PRESSURE VESSEL DIVISION Rev. 1 06/2003


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT


NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shanghai Rego Flow Technology Co., Ltd.	
MANUFACTURERS ADDRESS: 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China	
PLANT LOCATIONS: Refer scope document # 16046s-2	
<p>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>. (Meeting CNSC or ASME requirements)</p>	<p>TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3 2018 Edition</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div style="text-align: center; font-size: 2em; font-weight: bold; margin: 10px 0;">  </div>	
<p>TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/></p> <p>CAST <input type="checkbox"/> OTHER <input checked="" type="checkbox"/></p> <p>DESCRIBE OTHER:</p>	
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Refer scope document # 16046s-2</p> <p>Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131-SER</p>	

DECLARATION:
 I, Zachary Ruben (see note 3) employed by Shanghai Rego Flow Technology and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by CCC as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: 
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR
OFFICIAL SEAL

This space for Regulatory Authority use	
This registration must be revalidated after ten (10) years from the date of ACCEPTED	
CRN: <u>OC23020.5</u>	PROVINCE OF PRINCE EDWARD ISLAND COMMUNITIES, LAND & ENVIRONMENT C.R.N. <u>OC23020.59</u> DATE: <u>March 5/21</u>  INSPECTION SERVICES SECTION BOILER/PRESSURE VESSEL BRANCH Sect. 1.0 - Fittings Rev. 1 06/2003
FID#: <u>1704</u> RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. CRN expires Feb.19th, 2031 - DG	


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Engineered Controls International LLC	
MANUFACTURERS ADDRESS: 100 Rego Drive, Elon, NC 27244, USA	
PLANT LOCATIONS: Refer scope document # 16046s-2	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY	
<input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNCS or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2018 Edition
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT 	TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: Refer scope document # 16046s-2 Calculation # 16046c-2 RD, scope document # 16046s-2 and Main dwg# RS3131 SER	

DECLARATION:

I, Zachary Rubeor (see note 3) employed by Engineered Controls International and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DQC Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Rubeor
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR THE
OFFICIAL SEAL

This space for Regulatory Authority use	
This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C23020.5</u>	Newfoundland Labrador Service NL
FID#: <u>1704</u>	Registered <u>0C23020.50</u>
RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F	Date <u>21/03/05</u>
Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	Engineering and Inspection Services Registered by <u>[Signature]</u>
CRN expires Feb 19th, 2031 - DG	UNDER THE AUTHORITY OF THE PUBLIC SAFETY ACT AND THE BOILER, PRESSURE VESSEL AND COMPRESSED GAS REGULATIONS Sect. 1.0 - Fittings Rev. 1 06/2003


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shanghai Rego Flow Technology Co., Ltd.	
MANUFACTURERS ADDRESS: 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China	
PLANT LOCATIONS: Refer scope document # 16046s-2	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY	
<p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>. (Meeting CNSC or ASME requirements)</p>	<p>TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center">ASME B31.3 2018 Edition</p>
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	
	
<p>TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/></p> <p>CAST <input type="checkbox"/> OTHER <input type="checkbox"/></p> <p>DESCRIBE OTHER:</p>	
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:	
<p>Refer scope document # 16046s-2</p> <p>Calculation # 16046c-2 RD, scope document # 16046s-2 and Main dwg# RS3131-SER</p>	

DECLARATION:
 I, Zachary Ruben (see note 3) employed by Shanghai Rego Flow Technology, and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by CQC as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Ruben
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths or Notary Public: (sign) _____

USE THIS SPACE FOR OFFICIAL SEAL

This space for Regulatory Authority use	
This registration must be revalidated after ten (10) years from the date of acceptance	
CRN: <u>0C23020.5</u>	Newfoundland Labrador Service NL
FID#: <u>1704</u>	Registered <u>0623020.50</u>
RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F	Date <u>21/03/05</u>
Notes:	Engineering and Inspection Services
1. All fittings shall be registered in the name of the Manufacturer.	Registered by <u>[Signature]</u>
2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.	UNDER THE AUTHORITY OF THE PUBLIC SAFETY ACT AND THE BOILER, PRESSURE VESSEL AND COMPRESSION FITTINGS REGULATION 2003
3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.	
4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	
CRN expires Feb.19th, 2031 - DG	

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Engineered Controls International LLC	
MANUFACTURERS ADDRESS: 100 Rego Drive, Elon, NC 27244, USA	
PLANT LOCATIONS: Refer scope document # 16046s-2	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>. (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center">ASME B31.3 2018 Edition</p>
<p align="center">SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div align="center" style="font-size: 2em; font-weight: bold; margin: 10px 0;">REGO</div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/></p> <p>CAST <input type="checkbox"/> OTHER <input type="checkbox"/></p> <p>DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Refer scope document # 16046s-2</p> <p>Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131 SER</p>	

DECLARATION:

I, Zachary Rubear (see note 3) employed by Engineered Controls International and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DQC Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Rubear

Declared before me at _____

This 19th day of February AD 2021

Commissioner of Oaths
or Notary Public: (sign) _____

USE THIS SPACE FOR AN
OFFICIAL SEAL

<p align="center">This space for Regulatory Authority use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>0C23020.5</u></p> <p>FID#: <u>1704</u></p> <p>RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F</p> <p><small>Notes:</small></p> <ol style="list-style-type: none"> 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. <p>CRN expires Feb. 19th, 2031 - DG</p>	
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR


MANUFACTURERS NAME: Shanghai Rego Flow Technology Co., Ltd.	
MANUFACTURERS ADDRESS: 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China	
PLANT LOCATIONS: Refer scope document # 16046s-2	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY	
<input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> . (Meeting CNSC or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2018 Edition
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	
	TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:	
Refer scope document # 16046s-2	
Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131-SER	

DECLARATION:

I, Zachary Ruben (see note 3) employed by Shanghai Rego Flow Technology and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by CQC as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Ruben
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR
OFFICIAL SEAL

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C23020.5</u>	
FID#: <u>1704</u>	
RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. CRN expires Feb.19th, 2031 - DG	

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Engineered Controls International LLC	
MANUFACTURERS ADDRESS: 100 Rego Drive, Elon, NC 27244, USA	
PLANT LOCATIONS: Refer scope document # 16046s-2	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center">ASME B31.3 2018 Edition</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <p align="center">REGO.</p>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Refer scope document # 16046s-2</p> <p>Calculation # 16046c-2 RD, scope document # 16046s-2 and Main dwg# RS3131 SER</p>	

DECLARATION:
 I, Zachary Rubear (see note 3) employed by Engineered Controls International and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DQC Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Rubear
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR
OFFICIAL SEAL

<p align="center">This space for Regulatory Authority use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>OC23020.5</u></p> <p>FID#: <u>1704</u></p> <p>RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F</p> <p><small>Notes:</small></p> <ol style="list-style-type: none"> All fittings shall be registered in the name of the Manufacturer. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. <p>CRN expires Feb 19th 2031 - DG</p>	 <p>Northwest Territories</p> <p>REGISTERED UNDER THE AUTHORITY OF THE BOILER AND PRESSURE VESSEL ACT.</p> <p>C.R.N. <u>OC23020.5T</u></p> <p>SIGNED <u>[Signature]</u></p> <p>DATE <u>MARCH 5 2021</u></p> <p align="right">163.00</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shanghai Rego Flow Technology Co., Ltd.	
MANUFACTURERS ADDRESS: 6889 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China	
PLANT LOCATION: Refer scope document # 16046a-2	
<p>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>. (Meeting CNSC or ASME requirements)</p>	<p>TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3 2018 Edition</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <p align="center">REGO.</p>	
<p>TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/></p> <p>CAST <input type="checkbox"/> OTHER <input type="checkbox"/></p> <p>DESCRIBE OTHER:</p>	
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Refer scope document # 16046a-2</p> <p>Calculation # 16046a-2 R0, scope document # 16046a-2 and Main dwg# RS3131-SER</p>	

DECLARATION:
 I, Zachary Ruben (see note 3) employed by Shanghai Rego Flow Technology, and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by COG as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Ruben
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR OFFICIAL SEAL

<p align="center">This space for Regulatory Authority use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>0C23020.5</u></p> <p>FID#: <u>1704</u></p> <p>RS3131 SER relief valve (Not for primary over pressure protection). 480psl @ -40F to 165F</p> <p><small>Notes:</small></p> <ol style="list-style-type: none"> All fittings shall be registered in the name of the Manufacturer. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. <p>CRN expires Feb.19th, 2031 - DG</p>	 <p>Northwest Territories</p> <p>REGISTERED UNDER THE AUTHORITY OF THE BOILER AND PRESSURE VESSEL ACT.</p> <p>C.R.N. <u>0C23020.5</u></p> <p>SIGNED <u>[Signature]</u></p> <p>DATE <u>MARCH 5 2021</u></p> <p><small>Subc. 1.0 - Fittings Rev. 1 06/2003</small></p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Engineered Controls International LLC	
MANUFACTURERS ADDRESS: 100 Rego Drive, Elon, NC 27244, USA	
PLANT LOCATIONS: Refer scope document # 16046s-2	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>. (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center">ASME B31.3 2018 Edition</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> 	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Refer scope document # 16046s-2</p> <p>Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131 SER</p>	

DECLARATION:
 I, Zachary Rubear (see note 3) employed by Engineered Controls International and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DQC Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachary Rubear
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR
OFFICIAL SEAL

<p align="center"><small>This space for Regulatory Authority use</small></p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>0C23020.5</u></p> <p>FID#: <u>1704</u></p> <p>RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F</p> <p><small>Notes:</small></p> <ol style="list-style-type: none"> All fittings shall be registered in the name of the Manufacturer. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. <p>CRN expires Feb 19th, 2031 - DG</p>	<div style="text-align: center;">  <p>NUNAVUT</p> <p>Boilers and Pressure Vessels Act</p> <p align="center">REGISTERED</p> <p>CRN: <u>0C23020.5N</u></p> <p>Date: <u>MARCH 5, 2021</u></p> <p>Signed: _____ <small>Chief Inspector</small></p> </div> <p align="center">Territorial Registration Fee</p>
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shanghai Rego Flow Technology Co., Ltd.	
MANUFACTURERS ADDRESS: 6999 Chuansha Rd., B11, Chuansha Industry Park Shanghai, China	
PLANT LOCATIONS: Refer scope document # 16046s-2	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY <input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2018 Edition
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT <div style="text-align: center; font-size: 2em; font-weight: bold; letter-spacing: 0.5em;">REGO</div>	
TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:	
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: Refer scope document # 16046s-2 Calculation # 16046c-2 R0, scope document # 16046s-2 and Main dwg# RS3131-SER	

DECLARATION:
 I, Zachery Ruben (see note 3) employed by Shanghai Rego Flow Technology, and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by CQC as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Zachery Ruben
 Declared before me at _____
 This 19th day of February AD 2021
 Commissioner of Oaths
 or Notary Public: (sign) _____

USE THIS SPACE FOR OFFICIAL SEAL

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C23020.5</u> FID#: <u>1704</u> RS3131 SER relief valve (Not for primary over pressure protection). 480psi @ -40F to 165F Note: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. CRN expires Feb.19th, 2031 - DG	 NUNAVUT Boilers and Pressure Vessels Act REGISTERED CRN <u>0C23020.5 N</u> Date <u>MARCH 5, 2021</u> Signed <u>[Signature]</u> Chief Inspector Territorial Registration Fee